

## TECHNISCHE HOCHSCHULE NÜRNBERG GEORG SIMON OHM



## **CERTIFICATE**



FIBALON®

This is to certify by the laboratory of the Georg Simon Ohm University of Applied Sciences Nuremberg that the polymer-fiber-filter "FIBALON®", developed and manufactured by FIBALON® has a filter efficiency of 99%.

FIBALON® offers also an extremely high selectivity for particles above 10 micron and a pressure difference of only 0.145 psi as well.

The turbidity is in a range of 0.1 to 0.5 FNU.

Issued Date:

Nuremberg, 20. September 2013

Spelial Ant

Prof Dr. Aust